# Pool Operators Weekly Report

Vessel: _____ Week of: _____

| | Sunday | | | Monday | | | Tuesday | | | Wednesday | | | Thursday | | | Friday | | | Saturday | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Time | Disinfectant Residual | pH | ORP | Disinfectant Residual | pH | ORP | Disinfectant Residual | pH | ORP | Disinfectant Residual | pH | ORP | Disinfectant Residual | pH | ORP | Disinfectant Residual | pH | ORP | Disinfectant Residual | pH | ORP |
| Open | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | |
| Close | | | | | | | | | | | | | | | | | | | | | |
| Temperature | | | | | | | | | | | | | | | | | | | | | |
| Total Chlorine | | | | | | | | | | | | | | | | | | | | | |
| Filter Pressure - Influent | | | | | | | | | | | | | | | | | | | | | |
| Filter Pressure - Effluent | | | | | | | | | | | | | | | | | | | | | |
| Flow rate (Before opening) | | | | | | | | | | | | | | | | | | | | | |
| Flow rate (Last hour open) | | | | | | | | | | | | | | | | | | | | | |

| CHEMICAL ADDITIONS | | | | | | WEEKLY READINGS | | | |
|---|---|---|---|---|---|---|---|---|---|
| DATE | TIME | CHEMICAL | AMOUNT | REASON | INITIAL | DATE | CALCIUM HARDNESS | TOTAL ALKALINITY | CYANURIC ACID |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

| Standard Operating Ranges | |
|---|---|
| Water Temp:<br>82 – 84 degrees (pool)<br>102-104 degrees (spa) | Total Alkalinity: 80 - 120ppm |
| ORP:<br>700 mV minimum (pool)<br>650 mV minimum (spa) | Calcium Hardness: 300 - 400ppm |
| Chlorine:<br>1.0 – 10.0 ppm (pool)<br>2.0 – 10.0 ppm (spa) | pH: 7.2 – 7.8 |

| BACKWASH | | | FILTER CLEANING | | | DRAIN | | |
|---|---|---|---|---|---|---|---|---|
| Date | Time | Initial | Date | Time | Initial | Date | Time | Initial |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |